



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 24/07/2025

Shift: A

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 84	OLr acted	reset	11:20:00	11:25:00	
2	OHP	CO 68	OLR acted	reset	11:30:00	11:35:00	
3	OHP	CO 33M brc	LT slow movement	checked found all ok,CT speed in 3rd ,kept in 1st	08:47:00	09:00:00	
4	OHP	BRC on CO 33M	LT not taking place,drive trips in overload	reset	09:30:00	09:45:00	
5	CHP	CC 33	trips in OLR,due to jamming dacksheet	reset,informed operation	08:15:00	08:20:00	3 times
6	CHP	SCR 9 CC 104	slewing not working,MPr trips in e/f	MPR reset	09:10:00	09:20:00	
7	CHP	CC 31 S3	S3 LT not working,overload,track full jammed	reset,informed operation	10:15:00	10:25:00	
8	CHP	CC 104 scr9	LT not working,OT acted	OT released	11:50:00	12:05:00	
9	CHP	C 105 SCR 7	LT not working,OT acted	OT releasd	12:55:00	13:05:00	
10	CHP	CC 113 A	OLR acted	reset	11:05:00	11:10:00	
11	WT	CO 3(B)	mpcb trips due to overload	made it on	12:45:00	12:50:00	