



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 08/06/2025

Shift: C

Incharge(s): Saurabh Kumar Yadav, K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 11	STOPPING ON ZSS fault, ZS PROBE DAMAGED	PROBE REPLACED	22:15:00	22:40:00	
2	OHP	CO 9	OLR ACTED	RESET	04:55:00	05:10:00	
3	OHP	CO 33M	OLr acted	reset	23:00:00	23:10:00	
4	OHP	WOBR 29	LT not taking place, m4 olr acted	reset	23:20:00	23:30:00	
5	OHP	BRC on co 28	LT not taking Place, m6 tripped olr	reset	00:25:00	00:40:00	
6	OHP	WOBR on CO 26	B/c zss acted, stone stucked in zss cage	stone removed	02:25:00	02:40:00	
7	OHP	TBS on CO 21	right luff limit acted	limit released	03:00:00	03:15:00	
8	CHP	TT ON CO26	LT OLR ACTED	RESET	03:05:00	03:15:00	
9	CHP	CC 36 SCR1	BC not running, olr acted	reset	22:00:00	22:10:00	
10	CHP	CC 32 SCR5	LT not taking place, drive tripped in ol	reset it done	03:37:00	03:47:00	
11	CHP	ALL machine signal problem	micrologix plc comm. problem	micrologix power recycle done	22:45:00	23:00:00	2 times
12	CHP	CC 54	OLr acted	reset	02:20:00	02:25:00	3 times
13	CHP	CC 131	olr acted	reset	01:30:00	01:35:00	



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 08/06/2025

Shift: C

Incharge(s): Saurabh Kumar Yadav, K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
14	CHP	CC 58	olr acted	reset	05:30:00	05:35:00	2 times
15	WT	cp 3	NO MOVEMENT, 3A1 contactor got stucked	contactor opened and cleaned than ok	01:20:00	01:40:00	
16	WT	CP2 and CP3	no movement, communication problem	power recycle done of PLC	03:15:00	03:30:00	
17	WT	OT 4	D1 tripped in PGF1 fault	reset	04:30:00	04:35:00	
18	WT	OP4	pusher no movement @ coupling, D-6 OLR acted	reset	04:40:00	04:55:00	
19	WT	EOT coal	hoist not working, control side all ok, remote keypad problem	check control ckt all ok, local hoist working fine, informed operation remote keypad having problem	04:00:00	04:25:00	