



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 19/02/2026

Area: WT

Equipment	Job
OP 10	Trolley line checked from maintenance zone to Tippler end found OK
OP 10	D B R room sheets closed all sides (welding to be done)
OP 10	AC control panel fixed inside D B R room
OP 10	Forward End Limit and striker installed and tested
OP 10	control cable laid from Forward Limit Switch to C J B and connected to identified cores
MIS	1.5 sq mm 4 pair screen cable received from Utility Dept.
OP 1,3 and 6	After rake maintenance done