



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 15/08/2025

Shift: B

Incharge(s): Amit Roy,K SANKARA RAO

| Sl No | Area | Equipment     | Problem  | Action   | From                             | To                               | Remarks                      |
|-------|------|---------------|--|--|----------------------------------|----------------------------------|------------------------------|
| 1     | OHP  | WOBR ON CO-26 | SLEW NOT MOVING CHECKED AND FOUND DRIVE TRIPPED(2TIMES)            | RESET DONE   | 16:30:00<br>17:30:00             | 16:50:00<br>17:40:00             |                              |
| 2     | OHP  | WOBR ON CO-26 | SLEW NOT WORKING DRIVE TRIP  | SLEW SPEED DECREASED WITH POTENTIOMETER AND DRIVE RESET DONE | 18:00:00                         | 18:20:00                         |                              |
| 3     | OHP  | CO-84         | REPORTED RED CHECKED AND FOUND OLR ACTED (2TIMES)                  | RESET DONE   | 17:50:00<br>19:00:00             | 18:00:00<br>19:10:00             |                              |
| 4     | OHP  | CO-35         | RED CHECKED AND FOUND OLR ACTED                                    | RESET DONE   | 19:10:00                         | 19:20:00                         |                              |
| 5     | OHP  | BRC ON CO-28  | B/C NOT RUNNING CHECKED AND FOUND OLR ACTED                        | RESET DONE   | 20:15:00                         | 20:30:00                         |                              |
| 6     | OHP  | WOBR ON CO-25 | B/C STOPPING ON ZSS CHECKED AND FOUND ZSS CAGE STUCK UP WITH STONE | STONE REMOVED AND TESTED OKAY                                | 20:15:00                         | 20:30:00                         |                              |
| 7     | OHP  | CC-58 TT      | FESTOON CABLE DAMAGED  | JOINT DONE THEN OK   | 15:25:00                         | 16:00:00                         |                              |
| 8     | OHP  | CO-113        | Reported not healthy   | MCCB tripped.Made on   | 21:15:00                         | 21:20:00                         | Due to over material on belt |
| 9     | CHP  | CC-104 SCR-9  | LT NOT TAKING PLACE CHECKED AND FOUND FAULT RESET NOT PRESSED      | FAULT RESET DONE AND TESTED OKAY                             | 16:10:00                         | 16:25:00                         |                              |
| 10    | CHP  | CC-34 SCR-2   | LT NOT TAKING PLACE O/T ACTED                                      | O/T RELEASED THAN OK   | 16:10:00                         | 16:20:00                         |                              |
| 11    | CHP  | CC-51         | OLR TRIP (3TIMES)  | RESET DONE   | 16:15:00<br>17:20:00<br>21:10:00 | 16:25:00<br>17:25:00<br>21:20:00 |                              |
| 12    | CHP  | CC-54         | OLR ACTED  | REST DONE  | 18:05:00                         | 18:10:00                         |                              |



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 15/08/2025

Shift: B

Incharge(s): Amit Roy, K SANKARA RAO

| Sl No | Area | Equipment | Problem              | Action                  | From     | To       | Remarks               |
|-------|------|-----------|----------------------|-------------------------|----------|----------|-----------------------|
| 13    | CHP  | CC-113    | STOPPING ON ZSS      | DUE TO MATERIAL JAMMING | 18:20:00 | 18:25:00 | INFORMED TO OPERATION |
| 14    | CHP  | CC125     | Reported not healthy | OLR acted.reset done    | 21:30:00 | 21:35:00 |                       |