



वी.एस.पी.  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 06/02/2026

## Area: OHP

Equipment	Job
co-10,13	motor and panel side ppm is done
bf-1a,2a,7a,8a,9a,vs-1a,2a,3a,4a,5a,not 14b,14c,16a,16b,16c,17a,17b,17c	safety devices ppm is done
jh o-14,bpc-1 h/e hoists	ppm is done. jh o-14 welding machine cable proper termination done at power source.
co-33a,35a,37a	safety devices ppm is done. co-31a motor termination is removed as motor is shifted for mechanical job, re-termination needs to be done after their clearance.
co-7,10,13	motor and panel side ppm is done
tbs-1 on co-22 ; tbs-7 on co-19,co-19,21,23	motor and panel ppm is done.
BRC-2 on co-31	HT transformer is changed and tested. old transformer is shifted to hvmcc-1 .