



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 26/04/2025

Shift: A

Incharge(s): Lal Singh, Arnab Roy

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC on co 34	LT not working	drive tripped on ol ... reset done	07:10:00	07:30:00	
2	OHP	co-33m brc	LT not working	wrong complaint	08:25:00	08:45:00	
3	CHP	cc-35 S-1	do drives starting	main in off ... made on	06:40:00	07:00:00	
4	CHP	cc-35	BRS not healthy	fuse blown in CJB ... replaced ... and JOD also acted .. reset done	06:30:00	07:00:00	
5	CHP	cc-40 scr-6	luff up not working	luff up limit stuck ...made free	08:30:00	09:25:00	
6	CHP	cc-33 scr-4	Lt not working ... drive tripping due to jamming	informed operation for cleaning	12:30:00	12:50:00	
7	CHP	cc-39	direct mode remove request	removed	13:00:00	13:05:00	
8	CHP	cc-104 scr -9	signal missing and no drive running	plc power recycled... drives tested ... ohp side boom position limit problem ...bypassed in io rack .. reclaiming mode also not coming .. bypassed in io rack ..slew oil cooler output flickering ... made on with pump on	10:45:00	11:45:00	reclaiming mode ... position to ohp side ..and oil cooler output to be checked later
9	WT	op-7	breaker tripped	made on	11:05:00	11:20:00	
10	WT	ot-2	drive 2 tripped in PGF1 fault	reset done	11:05:00 12:00:00	11:10:00 12:05:00	
11	IOSA	L&T; wobr	main not getting on	auxiliary and control was in off ... made on	07:40:00	07:55:00	