



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 02/06/2025

Area: IOSA

| Equipment | Job |
|-------------------|---|
| MISC | TWO CHAIN PULLEY DEFECTS RECTIFIED AND MADE READY FOR USAGE. |
| ELECTRICAL SHED | HOUSE KEEPING IS IN PROGRESS |
| MISC | 55KW SPARE MOTOR OF OC-37A , MEGGERED AND TRIAL RUN IS IN PROGRESS. |
| ELECTRICAL HOISTS | WORKING STATUS CHECKED AND DEFECTS RECORDED FOR HOISTS AT OC-11A, OJH-8A, OJH-5A,OC-7C HEAD and TAIL END , OC-7A H/E. |
| OC-3A | PPM DONE ON MOTOR AND FIELD DEVICES |