



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 08/02/2026

Incharge(s): Amit Roy

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC on CO-28	No operations taking place	ACB tripped.Made on and tested okay	17:05:00	17:20:00	
2	OHP	CO-26	Reported tripped	OLR acted.Reset done	17:15:00	17:35:00	
3	OHP	TBS on CO-19	LT not taking place	Brake MCB tripped.Chp side no brake but cable fault found.Cable removed and tested okay	14:30:00	14:45:00	
4	OHP	VS-1A	Reported tripped	OLR acted.Reset done	18:00:00	18:05:00	
5	OHP	WOBR on CO-29	Slewing not taking place	Drive tripped.Reset done	19:20:00	19:30:00	
6	CHP	CC-34 SCR-7	LT not taking place	PCRD tension acted.Released and tested okay	19:15:00	19:30:00	
7	CHP	Cc-131	Reported tripped	OLR acted.Reset done(2 times)	19:05:00	21:00:00	
8	CHP	Cc-51	MPD tripped	Reset done	21:30:00	21:35:00	
9	CHP	CC-29	ZSS bypassed in A-shift	Probe changed and tested okay.	19:52:00	20:06:00	
10	IOSA	OC-37A	Reported BRS acting	Mechanical BRS contacts tightened	14:50:00	15:00:00	