



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 04/06/2025

Area: IOSA

| Equipment | Job |
|-------------------|--|
| BLENDER RECLAIMER | POWER CABLE TERMINATION DONE AND TRIAL RUN TAKEN AFTER HT CABLE BOOTING AND LUGGING BY DNW TEAM. |
| BLENDER RECLAIMER | BLENDER TO YARD CONVEYOR ZSS CAGE GOT STRUCK. REPLACED WITH SPARE. |
| OC-31A | PPM DONE ON MOTOR and FIELD DEVICES |