



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 03/07/2025

Shift: C

Incharge(s): Lal Singh, Arnab Roy

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 33M	OLR acted	reset done	01:05:00	01:10:00	
2	OHP	WOBR on CO 6A	BC not running interlock cage tied up	released the cage , tested then ok	03:30:00	03:45:00	
3	OHP	CO 13A	Pull chord to be bypassed as per operation request	bypass done	03:18:00	03:25:00	
4	OHP	TBS on CO 22	Left luff OLR acted due to material jamming near boom	reset done	22:22:00	22:40:00	
5	OHP	TBS on CO 24	Chute sensor not working	Gate changed but chute sensor not changed , electrically found ok. Informed to operation	23:45:00	23:55:00	
6	OHP	CO 26	OLR acted	reset done	01:48:00	01:58:00	
7	OHP	WOBR on CO 26	Interlock cage problem	cage fixed properly	04:00:00	04:20:00	
8	OHP	VS 1A	Tripping on phase fault	meggaring done , found ok . Tested in local	04:50:00	05:30:00	
9	CHP	CO 29 TT	Chute sensor not healthy	Cable joint problem , rejoin done . Also in MCB near JB one phase connection loose, tightned	22:00:00	23:45:00	
10	CHP	CC 54	Tripped on overload	reset done	01:30:00 05:00:00	01:35:00 05:05:00	
11	CHP	CC 131	Tripped on overload ( 3 times)	reset done	01:15:00	03:20:00	
12	CHP	CC 33	Tripped on overload	reset done	23:00:00	23:10:00	
13	CHP	CC 32 SCR 5	LT not working	M 2 MPCB tripped , RESET DONE	01:10:00	01:20:00	



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 03/07/2025

Incharge(s): Lal Singh, Arnab Roy

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
14	CHP	CC 33 , SCR 4	Slew not working , oil level low	Informed to mechanical	01:50:00	02:10:00	
15	CHP	CC 40 , SCR 6	BC not running	Chute sensor acted due to jamming , informed operation for cleaning	03:30:00	03:45:00	
16	CHP	CC 104 , SCR 9	Slew not working	Slew limit found ok, asked operator to stop boom . Emergency stop by operator , PLC showing Eb03 error	05:20:00	06:00:00	Checking going on
17	WT	CO 3 Belt drive	tripped on overload 2 times due to jamming	reset done	01:20:00	01:30:00	
18	WT	OP 1	Not moving	initial problem , tipler movement done, then ok	03:50:00	04:00:00	
19	IOSA	OC 13A	Mechanical BRS acted	reset	04:00:00	04:30:00	