



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 02/12/2025

Area: IOSA

| Equipment         | Job   |
|-------------------|---|
| OC-19A            | HEAD END LIGHTING CIRCUIT DEFECTS RECTIFIED. SUFFICIENT LIGHTING ARRANGED. DEFECTIVE LIGHT FITTINGS REMOVED AND SHIFTED TO ELECTRICAL SHED. |
| OC-27A            | GALLERY LIGHTING CIRCUIT DEFECTS RECTIFICATION IS IN PROGRESS.  |
| OC-9A             | GALLERY AND JUNCTION HOUSE LIGHTING CIRCUIT DEFECTS RECTIFICATION IS IN PROGRESS.   |
| OC-11A            | GALLERY AND JUNCTION HOUSE LIGHTING CIRCUIT DEFECTS RECTIFICATION IN PROGRESS   |
| WOBR-FLS          | TRIAL RUN TAKEN AND CHECKED ALL FUNCTIONS.  |
| BLENDER RECLAIMER | BUCKET WHEEL -2 ZSS PROBE ADJUSTMENT DONE.  |
| OC-18A            | PPM DONE ON MOTOR AND FIELD DEVICES.  |