



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 19/09/2025

Incharge(s): K SANKARA RAO

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	WOBR ON CO-26	SLEW NOT WORKING CHECKED OLR ACTED	OLR RESET DONE	07:05:00	07:25:00	
2	OHP	TW-6	OLR ACTED	RESET DONE	07:30:00	07:40:00	
3	OHP	WOBR ON CO-26	LT NOT TAKING PLACE CHECKED PCRD CHAIN BROKEN	INFORMED TO MECHANICAL AND PCRD CABLE LOOP GIVEN AND CLEARANCE GIVEN TO OPERATION	12:20:00	12:30:00	MECHANICAL JOB GOING ON
4	OHP	BRC ON CO-28	LT NOT TAKING PLACE PCRD O/T ACTED	RELEASED	13:20:00	13:35:00	
5	CHP	CC-28	OLR ACTED	RESET DONE	10:30:00	10:40:00	
6	CHP	CO-54	OLR ACTED	RESET DONE	08:25:00	08:35:00	
7	CHP	CC-51	FEEDING CONVEYOR OLR ACTED (3TIMES)	RESET DONE	08:20:00 12:30:00 13:05:00	08:30:00 12:40:00 13:20:00	
8	CHP	CC-108	OLR ACTED	RESET DONE	11:00:00	11:05:00	
9	CHP	CC-112 SCR-8	LUFF NOT WORKING DUE TO OIL LOW LEVEL	INFORMED TO MECHANICAL	10:30:00	10:55:00	
10	CHP	CC-37 SCR-7	SLEW NOT WORKING CHECKED AND FOUND SLEW BREAK ALARM ACTED	SPIDER ALARM RESET DONE THAN OK	12:00:00	12:15:00	