



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 18/12/2025

Incharge(s): G Eswara Rao

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co 33m	tripped on olr 2times	reset done	10:25:00 11:40:00	10:30:00 11:45:00	
2	OHP	co 84	tripped on thermal olr.	reset done.	09:40:00	09:45:00	
3	OHP	wobr on co 26	slew not taking place/drive tripped on olr	reset done	13:00:00	13:13:00	
4	CHP	cc 130	tripping on healthy.	checked and found mech. brs acting/by passes at i/o rack	07:05:00	07:40:00	ele.brs alredy bypassed
5	CHP	cc 201	tripped on olr	reset done	08:30:00	08:35:00	
6	CHP	scr 5 on cc32	bc not running/olr acted due jamming./inform to operation to clear the material	reset done.	09:30:00	09:45:00	
7	CHP	cc 44	tripped on olr	reset done	10:30:00	10:35:00	
8	CHP	scr 9 on cc104	slew not running/olr acted	reset done.	11:40:00	11:50:00	
9	CHP	cc 54	tripped on olr.	reset done.	12:20:00	12:25:00	
10	CHP	cc 130	jod (mech.brs) kept in ckt	in ckt	10:30:00	10:40:00	