



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 26/08/2025

Incharge(s): Amit Roy, K SANKARA RAO

Shift: C

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|--------------------|--|--|----------|----------|-------------------------|
| 1 | OHP | BRC ON CO-28 | B/C NOT RUNNING CHECKED AND FOUND POWER MCCB TRIP | POWER MCCB MADE ON | 04:00:00 | 04:15:00 | |
| 2 | OHP | WOBR ON CO-29 | LT NOT TAKING PLACE CHECKED AND FOUND M-4 OLR ACTED | OLR RESET DONE | 04:15:00 | 04:30:00 | |
| 3 | OHP | OC-1A (BELT DRIVE) | OLR ACTED | OLR RESET DONE | 23:50:00 | 00:00:00 | |
| 4 | OHP | CO-4 | BELT KEPT IN LOCAL | TRIPPED ON OLR(3TIMES) | 00:00:00 | 05:00:00 | PRESENTLY IN LOCAL ONLY |
| 5 | CHP | CC-3 (BELT DRIVE) | OLR ACTED | OLR RESET DONE | 05:10:00 | 05:20:00 | |
| 6 | CHP | CC-58 ON TT | POSITION INDICATION NOT SHOWING CHECKED AND FOUND TT CABLE GOT CUT | TT CABLE RE JOINT DONE THAN OK | 23:15:00 | 23:40:00 | |
| 7 | CHP | CC-113 | REPORT STOPPING ON ZSS | CHECKED AND FOUND BELT SNAPPED | 05:05:00 | 05:15:00 | INFORMED TO MECHANICAL |
| 8 | CHP | CC-39 SCR-7 | B/C NOT MOVING | DISCHARGE CHUTE FOUND IN JAMMING CONDITION | 23:40:00 | 00:00:00 | INFORMED TO OPERATION |
| 9 | CHP | CC-125 | REPORTED NOT HEALTHY | OLR TRIPPED.RESET DONE | 00:00:00 | 00:10:00 | |
| 10 | CHP | CC-44 | REPORTED NOT HEALTHY | OLR ACTED.RESET DONE | 01:10:00 | 01:20:00 | |



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 26/08/2025

Incharge(s): Amit Roy, K SANKARA RAO

Shift: C

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|----------------|-------------------------|--|----------------------|----------------------|------------------------------|
| 11 | CHP | CC-38 SCR-6 | LT NOT WORKING | CHECKED AND FOUND MPCB1,2,3,6 TRIPPED DUE TO TRACK JAMMING.RESET DONE. | 03:45:00 | 03:55:00 | INFORMED TO OPERA TION |
| 12 | CHP | CC40 SCR-3 | REPORTED LT NOT WORKING | CHECKED AND FOUND LT DRIVE TRIPPED.RESET DONE(2TIMES) | 04:35:00 05:30:00 | 04:45:00 05:35:00 | |
| 13 | CHP | CC-40 SCR3 | SLEW NOT TAKING PLACE | LEFT LIMIT ACTED.RELEASED AND TESTED OKAY | 03:00:00 | 03:15:00 | |