



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 18/05/2025

Shift: B

Incharge(s): G Eswara Rao

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	op 6	f/reverse not taking place while reverse /bottom pad c clamp got damaged/acb tripped	c clamp replaced and acb made on then given clearance	14:30:00	15:20:00	no delay
2	OHP	co 26	tripped on olr	reset done	19:15:00	19:30:00	
3	OHP	co 15	pc acted/not getting reset	reset done in mpd through parametors reset	19:30:00	20:10:00	
4	CHP	scr 3 on cc38	It not taking place/drive tripped	reset done	14:30:00	14:40:00	
5	CHP	scr 2 on cc35	It not taking place/pcrd cable tension acted	tension released.	16:00:00	16:10:00	
6	CHP	R1 on cc31	bc stopping frequently/zss cage stuckup with material	cage made free then ok	19:35:00	19:50:00	
7	CHP	cc 131	tripped on olr	reset done	15:15:00	15:25:00	
8	CHP	RG 3	tripped on temp.	reset done	15:15:00	15:30:00	
9	WT	sca 1a	pullcord acted	pc reset done	17:25:00	17:45:00	
10	WT	ot4	side clamp signal missing/required not gettig	pressure setting changed by instrumentation	19:45:00	21:30:00	