



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 17/06/2025

Area: WT

Equipment	Job
others	Coupling fixed to spare 37 kw slip ring motor
cp-3	Panel and motor side ppm done and found D-5 motor Lug broken replaced with new lug.
cp-1	Panel and motor side ppm done