



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 05/12/2025

Incharge(s): Lal Singh,Lal Singh

Shift: A

| Sl No | Area | Equipment    | Problem                                    | Action                                | From                 | To                   | Remarks |
|-------|------|--------------|--|---------------------------------------|----------------------|----------------------|---------|
| 1     | OHP  | CO-25        | TRIPPED ON OLR                             | RESET DONE                            | 13:00:00<br>13:20:00 | 13:10:00<br>13:30:00 |         |
| 2     | OHP  | TT-4         | C/S SIGNAL NOT COMING ... FUSE BLOWN IN TT | FUSE REPLACED AND WIRE FIXED PROPERLY | 07:15:00             | 07:30:00             |         |
| 3     | OHP  | BRC ON CO-34 | BW-2 OLR TRIPPED                           | RESET DONE                            | 08:30:00             | 08:45:00             |         |
| 4     | CHP  | CC-40 SCR-2  | BW DRIVE TRIPPED                           | RESET DONE                            | 13:05:00             | 13:15:00             |         |
| 5     | CHP  | CC-51        | MPD TRIPPED (13 TIMES )                    | RESET DONE                            | 06:00:00             | 14:00:00             |         |
| 6     | CHP  | CC-54        | TRIPPED ON OLR (15 TIMES)                  | RESET DONE                            | 06:00:00             | 14:00:00             |         |
| 7     | CHP  | CC-28        | TRIPPED ON OLR                             | RESET DONE                            | 07:35:00             | 07:40:00             |         |
| 8     | CHP  | CC-29        | TRIPPED ON OLR                             | RESET DONE                            | 09:00:00<br>10:05:00 | 09:05:00<br>10:10:00 |         |
| 9     | CHP  | CC-112 SCR-8 | LT NOT MOVING                              | PCRD NOT HEALTHY ... RESET            | 13:00:00             | 13:10:00             |         |
| 10    | WT   | OP-9         | NOT MOVING MIDDLE PAD DISTURBED            | ADJUSTED                              | 09:15:00             | 09:35:00             |         |