



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 27/04/2025

Incharge(s): Lal Singh, Arnab Roy

Shift: A

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|-----------------|--------------------------------|--|----------|----------|-----------------------|
| 1 | OHP | BRC on CO 8A | BW 2 not running | Wrong complaint | 06:45:00 | 07:05:00 | |
| 2 | OHP | CO 33M | OLR acted | reset done | 06:55:00 | 07:05:00 | |
| 3 | OHP | CO 35 | OLR acted | reset done | 08:00:00 | 08:05:00 | |
| 4 | OHP | VF 2A | Chute sensor not getting reset | Coupling and V belt damaged . Informed to Mechanical and operation | 08:30:00 | 08:45:00 | |
| 5 | OHP | BRC on CO 28 | BW 2 not rotating | Fluid coupling and guide roller problem , informed to mechanical and operation | 09:30:00 | 09:45:00 | |
| 6 | OHP | BRC on CO 33M | Hydraulic pump not starting | Oil level low, informed to mechanical | 10:30:00 | 11:00:00 | |
| 7 | CHP | CC 33 , SCR 4 | LT not working | PCRD motor OLR tripped , reset done | 12:20:00 | 12:30:00 | |
| 8 | CHP | CC 114 | BRS bypassed | Operation requirement | 09:00:00 | 09:08:00 | again kept in circuit |
| 9 | CHP | CC 32 and CC 39 | BRS in bypass condition | Kept in circuit as per operation request | 12:00:00 | 12:25:00 | |
| 10 | CHP | CC 131 | Tripped | reset done, jamming in tail end. Informed operation | 09:55:00 | 10:00:00 | |
| 11 | CHP | CC 51 | ZSS acted | due to coal jamming , informed to operation | 13:15:00 | 13:20:00 | |