



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 26/09/2025

Area: CHP

Equipment	Job
RG building	All LT motors greasing done and screen area lighting improved
CC 51,51A	PPM was done
CC 39 S1	PCRD cable layering was done
CC 201`/222/223	Belt scale units maintenance was done
CC 42	BRS kept in ckt
CC 49/50	Staircase area 2nos lamp fixtures rectified
CC 222/223	Defective lamp fixtures removed and brought for rectification
CC 43/44	3 nos 50W LED lamps replaced
CM 18	Cleaning under progress
STACKER 3	HT cable damaged joint wrapper was replaced by DNW