



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 22/07/2025

Shift: B

Incharge(s): Amit Roy

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|---------------|----------------------------|---|----------------------------------|----------------------------------|-----------------------------------|
| 1 | OHP | TBS on CO-22 | LT not taking place | Drive tripped.Reset done | 16:00:00 17:30:00 | 16:15:00 17:45:00 | |
| 2 | OHP | TBS on CO-23 | LT not taking place | Power was in off condition.Power made on. | 17:40:00 | 17:50:00 | |
| 3 | OHP | CO-25 | Reported not healthy | OLR acted due to load on belt.reset done | 14:00:00 20:35:00 21:15:00 | 14:10:00 20:45:00 21:25:00 | |
| 4 | OHP | TBS on CO-7A | Left luff not taking place | Drive tripped.reset done | 20:35:00 | 20:45:00 | |
| 5 | OHP | CO-111 | Reported not healthy | Checked and found belt rubbing with pulley.Reset done | 17:00:00 | 17:10:00 | informed to operation |
| 6 | OHP | TT-1 on CO-14 | Flap gate not working | OLR acted.reset done | 19:25:00 | 19:30:00 | |
| 7 | CHP | CC-105 | Reported BRS not working | Checked and found working fine | 16:40:00 | 16:50:00 | Wrong complaint |
| 8 | CHP | CC-126 | Hoist not working | MCCB tripped.Made on and tested okay | 17:26:00 | 17:45:00 | |
| 9 | CHP | CC-104 scr -9 | B/C not healthy | Checked and found TUL chute jamming. | 17:44:00 | 18:10:00 | Informed to operation |
| 10 | CHP | CC-105 scr-7 | Slew not taking place | Spider alarm high temperature.cooler fan cable got cut. cable outgoing removed from mcc panel.spider reset done and tested okay | 18:43:00 | 19:15:00 | cooler fan cable joint to be done |
| 11 | CHP | CC-40 | BRS acted | BRS acted due to off centering. | 19:40:00 | 19:50:00 | informed to mechanical |



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 22/07/2025

Incharge(s): Amit Roy

Shift: B

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|--------------|----------------------|----------------------------|----------------------------------|----------------------------------|-----------------|
| 12 | CHP | CC-104 scr-9 | Lt not taking place | Checked and LT tested okay | 20:54:00 | 21:05:00 | wrong compliant |
| 13 | CHP | CC-54 | Reported not healthy | OLR acted.reset done | 14:45:00 18:50:00 21:30:00 | 14:50:00 18:55:00 21:35:00 | |