



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 02/05/2025

Area: IOSA

Equipment	Job
BLENDER RECLAIMER	LT THRUSTER BRAKES CHECKING DONE AND DEFECTIVE LINER RECTIFICATION TAKEN UP.
OC-2A,5A,23A,27A	MOTOR PROTECTION RELAYS PARAMETERS AND CONNECTIONS CHECKED
TBS- PCRD	CABLE GOT UN-WINDED DUE TO CABLE GUIDE CHAIN PROBLEM. RECTIFIED AND RE-WINDED POWER CABLE
OC-4A	
UPS BATTERY	
UPS	