



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 04/11/2025

Shift: B

Incharge(s): Nagendra Midde,Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TBS on co 19	drive tripped in OVN fault	reset again tripped,checked all motor M2 power cable insulation damaged,insulation provided	20:50:00	21:28:00	motor 2 DE cover bolt missed,to be replaced in G shift
2	OHP	BRC on Co 8A	b/w no movement,chain fallen	mechanical problem	21:10:00	21:20:00	
3	OHP	RSCO 10 A(C)	olr acted	reset	15:50:00	16:00:00	
4	OHP	TBS on Co 19	LT not 5taking place,drive tripped	reset	16:00:00	16:10:00	
5	OHP	CO 26	olr acted	reset	18:00:00	18:10:00	
6	OHP	RSco 6a	carriage drive tripped due to jamming	reset	16:30:00	16:40:00	
7	CHP	SCR 2 ON CC 34	B/C C/S ACTED	INFORMED TO OPRN	17:15:00	17:30:00	
8	CHP	SCR 8 ON CC 112	SLEW BREAK PRESSURE HEALTHY MISSING	INFORMED TO MECH	18:15:00	18:30:00	
9	CHP	CC 45	OLR ACTED	RESET	21:00:00	21:15:00	2 TIMES
10	CHP	CC 54	OLR ACTED	RESET	15:00:00	21:45:00	15 TIMES
11	CHP	CC 51	MPD TRIPPED ON OLR	RESET	15:30:00	21:45:00	6 TIMES
12	CHP	CC 117	OLR ACTED	RESET	17:50:00	18:05:00	
13	CHP	CC 51`	BELT SLIPPING	INFORMED TO MECH	15:45:00	15:55:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 04/11/2025

Shift: B

Incharge(s): Nagendra Midde, Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
14	CHP	RG2 F/G	OLR ACTED	RESET	18:15:00	18:25:00	
15	CHP	RG3	F/G	OLR ACTED	15:05:00	15:15:00	RESET
16	CHP	CC 131	OLR ACTED	RESET	21:55:00	22:00:00	
17	CHP	CC 29 T/T	CONTROL TRIPPED	MADE IT ON	14:25:00	14:35:00	