



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 29/07/2025

Area: WT

Equipment	Job
EOT Crane(O)	Control circuit checked,found OK bypass removed
OT 5	Hooper area lighting,circuit problem rectified
OP 8	panel and motor side ppm done
OP 2,3,4,6 and 7	after rake maintenance done