



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 15/01/2026

Incharge(s): Nagendra Midde

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 16	OLR ACTED	RESET	03:10:00 03:35:00 05:00:00	03:15:00 03:40:00 05:10:00	
2	OHP	CO 33M LT	PCRD O/T ACTED	RELEASED	03:00:00	03:10:00	
3	OHP	CO 33 M	OLR ACTED	RESET	00:00:00	00:10:00	
4	OHP	CO 26	OLR ACTED	RESET	02:10:00 02:45:00	02:20:00 02:50:00	
5	CHP	SCR 1 ON CC 34	B/C POSITION SWITCH PROBLEM	BYPASSED	04:20:00	04:35:00	
6	CHP	CC 51	FEEDING CONV ACTED	RESET	22:30:00	05:45:00	16 TIMES
7	CHP	CC 51	OLR ACTED	RESET	00:00:00	04:30:00	3 TIMES
8	CHP	CC 131	OLR ACTED	RESET	23:45:00	05:45:00	7 TIMES
9	CHP	CC 29	OLR ACTED DUE TO JAMMING	RESET	00:30:00	05:30:00	5 TIMES
10	WT	OP2	D5 OLR ACTED	MADE IT ON	22:20:00	22:35:00	3 TIMES