



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 21/02/2026

Shift: B

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC on Co 8A	bc not running,OLR acted	reset	16:10:00	16:25:00	
2	OHP	CO 34	OLR acted	reset	17:55:00	18:00:00	
3	OHP	BRC on CO32	bw1 and 2 not running,oil level low	informed mechanical	15:50:00	16:00:00	
4	OHP	BRC on CO 34	LT not working,OT acted	OT released,informed mechanical for guide problem	16:00:00	16:10:00	
5	OHP	co 20	NOT RUNNING,STOPPED in ZSS ,due to belt slipping,jamming at tail end	informed operation	19:25:00	19:35:00	
6	OHP	vf 19	mpcb tripped	made it on	21:00:00	21:10:00	
7	CHP	cc 51	mpd acted 9 times	reset	15:00:00	15:05:00	
8	CHP	CC 58	olr acted	reset	17:01:00	17:06:00	
9	CHP	CC 39 STK2	no power acb is in off	made on	14:45:00	14:55:00	
10	CHP	CC 108	olr acted	reset	19:55:00	20:00:00	
11	CHP	CC 37 SCR3	slew not working,low acc pressure and oil level	informed mech	21:30:00	21:40:00	
12	WT	OT 4	not rotating,D2 PGF1 fault and selector switch in brake mode	reset and kept in normal	15:00:00	15:15:00	
13	WT	CO 2	zss acted,return core cable loose	connection done properly	14:05:00	14:20:00	
14	WT	OT4	D2 tripped in pgf1 fault	reset	16:10:00	16:15:00	
15	WT	OT 4	tippler initial not came,probe problem	probe adjusted properly	17:00:00	17:15:00	



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 21/02/2026

Shift: B

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
16	IOSA	OC 37 A	BRS mechanical problem not getting reset,misalignment	properly adjusted	20:00:00	20:20:00	