



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 30/06/2025

Area: CHP

Equipment	Job
CC-52,CC-53,CC-54,CC-55,CC-56,CC-57,CC-58	ppm done
CC-219 lighting	Lighting faults rectification done
CC-41	panel and CJB side cable connections done. CJD and Emergency push button circuit separated. Feedback checked
SCR-1	PLC input and output cards tightness done
SCR-3	Luffing circuit checking done
SCR-9	New volktek media converter kept in line for upper house to lower house OFC communication
CC-41,CC-108	ppm done