



वी.एस.पी  
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL GENERAL SHIFT REPORT

Date: 30/07/2025

Area: OHP

Equipment	Job
CO 25 JOD	KEPT IN CIRCUIT
CO 29 TIS	KEPT IN CIRCUIT
CO 7 CO 6 PCS	KEPT IN CIRCUIT
CO 16	BRS KEPT IN CIRCUIT
HH3 FIRST FLOOR 3 NO 35W,	LIGHTING PROVIDED
CO 35, CO 78	PANNEL AND MOTOR PPM DONE
3 NO	ZSS CAGE MADE READY
CO 7A CURRENT TRANSDUCER REPLACED	FROM SPARE PANEL
LOSP2 GROUND LEVEL 200W-1, TIS ON CO 11A AREA 120-1	LIGHTS PROVIDED
LOSP2 RSCO1A H/E 120W-2 LIGHTS AND 35W-1 , LOSP2 STAIRCASE 30W- 5 NO	LIGHTS PROVIDED
CO 33A, 35A, 37A, 38B, 65, 68	GALLERY LIGHTING INSPECTION DONE
CO 31A, 33A, 35A, 37A, 38B, 65	HOIST PPM DONE
CO 70	SAFETY DEVICES PPM DONE
CO 34a, 36a, 38a, 38b	mMOTOR AND FEEDER PPM DONE