



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 16/01/2026

Shift: B

Incharge(s): Amit Roy

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC on CO-28	B/W-2 not running	B/W got struck.B/W reverse run done and made free and tested okay	14:20:00	14:35:00	Not an electrical delay
2	OHP	CO-26	Reported tripped	OLR acted.Reset done	18:40:00	18:45:00	
3	OHP	WOBR on CO-6A	B/W not running	Oil leakage found	15:40:00	15:50:00	Informed to mechanical
4	CHP	Cc-28	Reported tripped	OLR acted due to jamming.Reset done(2 times)	17:30:00	20:00:00	
5	CHP	Cc-40 SCR-2	signal missing	LT done and tested okay	15:15:00	15:30:00	
6	CHP	CC-34 SCR-1	B/C position	Cable rejoin done and kept in line	14:30:00	14:50:00	
7	CHP	Cc-107	Reported tripped	OLR acted.Reset done	20:20:00	20:25:00	
8	CHP	Cc-51	MPD tripped	Feeding conveyor stopped.reset done(2 times)	19:50:00	21:30:00	
9	CHP	CC-117	Reported tripped	OLR acted.Reset done	14:30:00	14:45:00	
10	WT	OP-2	Reported not moving	Drive-1 tripped.Reset done(3 times)	15:30:00	16:25:00	
11	WT	CO-2	Reported tripped	OLR acted.Reset done(2 times)	19:00:00	19:10:00	
12	WT	CO-2	Reported ZSS acting	Probe loose.tightened and tested okay	19:30:00	19:45:00	
13	IOSA	BRC	Reported B/C not running	Emergency acted at operator cabin side and P/C acted.Released and tested okay	16:00:00	16:15:00	