



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 27/06/2025

Area: WT

| Equipment           | Job                                                                                |
|---------------------|------------------------------------------------------------------------------------|
| OP 10               | D5 bed slots cutting and motor placement done                                      |
| OP 10               | D1 bed slots cutting,motor placement,alignment and termination done                |
| OP 10               | D 2,3 and 5 Motors removed from bed ,old couplings removed and new couplings fixed |
| OP 5,4,7,9 and CP 3 | after rake maintenance done                                                        |