



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 16/12/2025

Area: WT

Equipment	Job
OP 1	Panel and Motor side ppm done, found D4 slip ring damaged,bypassed it
OP 3	Panel and Motor side ppm done,D3 lug @ O/L replaced
OP 7	Location of New modem(cambium make) changed @OT 4 cabin
OP 3 and 6	After rake maintenance done