



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 14/02/2026

Incharge(s): Saurabh Kumar Yadav

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 1A	zss acted.belt stucked	informed operation its mech problem but not accepted,kept in local and run than jamming clear kept in PLC	03:30:00	03:45:00	
2	OHP	CO 25	olr acted	reset	03:25:00	03:35:00	2times
3	OHP	BRC on CO 32	B/C E stop acted	released	00:55:00	01:10:00	
4	OHP	CO 26	olr acted	reset	23:15:00	23:25:00	3 times
5	CHP	CC 51	MPD acted 2 times	reset	03:10:00	03:15:00	
6	CHP	CC 58	OLr acted	reset	03:20:00	03:25:00	
7	CHP	CC 53	FG mpcb tripped	made it on	05:05:00	05:10:00	
8	CHP	CC 213 on SCR9	b/c not running in reclaiming mode,operation problem	told operation to do slew at 45 degree	00:00:00	00:25:00	
9	CHP	CC 35 SCR 5	b/c not working, OLR acted	reset	00:30:00	00:40:00	
10	CHP	CC 105 SCR10	b/w not working,olr acted	reset	01:15:00	01:30:00	
11	CHP	CC 39 SCR6	slew not working,left limit acted	coal jamming informed operation	04:20:00	04:25:00	
12	CHP	CC 104 scr 7	LT not working,PCRD OT acted	released OT	05:15:00	05:20:00	