



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 24/05/2025

Shift: A

Incharge(s): V Balaji Naik, G Eswara Rao

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC on CO34	CT not working found limit cable got cut	Rejointed then ok	10:00:00	11:00:00	
2	OHP	CO29	OLR acted	Reset done	10:30:00	10:40:00	
3	OHP	WOBR on CO26	Slewing not working found drive fault	Reset done	11:00:00	11:30:00	
4	OHP	CO13	ZSS probe cable got cut	Rejointed then ok	12:00:00	12:30:00	
5	OHP	TIS ON CO 44	REPORTED RED/MPCB TRIPPED DUE GEAR BOX PROBLEM	MPCB MADE ON	13:40:00	13:50:00	
6	OHP	WOBR on CO26	ALL drives red found Emergency push button not released	get released then ok	14:00:00	14:00:00	05.00 pm to 05.15pm
7	OHP	CO33M	Over load acted	Reset done	14:00:00	14:00:00	04.10pm to 04.20pm
8	OHP	CO87	OLR acted	Reset done	14:00:00	14:00:00	04.15pm to 04.25pm
9	CHP	SCR1 on CC36	Luffing not working found jamming at limit area	Informed to operation and limit bypassed and removed after that	06:40:00	06:50:00	
10	CHP	SCR 2 on CC35	LT not not working found PCRD tension acted	Limit released then ok	10:30:00	10:40:00	
11	CHP	SCR5 on CC32	Slewing not working found 30 degree limit acted	Bypassed and again normalised	10:30:00	10:40:00	



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 24/05/2025

Incharge(s): V Balaji Naik,G Eswara Rao

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
12	CHP	VS1	MCCB tripped 3 times	Made on	07:40:00 08:25:00 10:15:00	08:00:00 08:50:00 10:30:00	Second time tripped VS1(37 kw) motor meggered and found motor one phase opened motor replaced with spare one
13	CHP	CC54	Over load trip 2 times	Reset done	09:45:00 09:55:00	09:50:00 10:00:00	
14	CHP	CC131	Over load trip 2 times	Reset done	08:35:00 10:20:00	08:40:00 10:35:00	
15	CHP	CC219	Emergency PB showing red found DE side Chute sensor acted	Chute sensor reset done Emergency PB ok	07:07:00	07:15:00	
16	CHP	CC222	ZSS acted found belt is in full load condition	Informed to operation	09:05:00	09:23:00	Cleaning under progress



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 24/05/2025

Shift: A

Incharge(s): V Balaji Naik, G Eswara Rao

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
17	CHP	CC36	ZSS acting frequently checked that Proximity sensor fault	Teperarily by passed as stacking is taking place	13:10:00	13:20:00	After belt stopping informed to change Proximity sensor
18	CHP	CC 36	zss proximit damaged	proximity switch replaced .then ok	14:00:00	14:30:00	
19	CHP	CC131	Over load acted	Reset done	14:00:00	14:00:00	04.50pm to 05.00pm
20	CHP	SCR5 on CO32	LT drive trip	Reset done	14:00:00	14:00:00	04.20pm to 04.30pm
21	CHP	Cc108	Healthy stop found PB problem	Temperarily bypassed then ok	14:00:00	14:00:00	05.30pm to 05.40pm
22	WT	CO3 belt	Over load trip	Reset done	12:20:00	12:25:00	
23	WT	OP3	D5 rotor contactor(5A1) got struck	Get released then ok	14:00:00	14:00:00	05.20pm to 05.30pm
24	IOSA	OC 3A	ZSS ACTED/cage problem	zss cage replaced then ok	06:45:00	08:10:00	