



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 02/12/2025

Area: CHP

Equipment	Job
JH C 15,16	Hoist panels maintenance was done
CC 12/13/15	GPL point lighting improved by providing 120W and 2 nos 70W fixtures replaced
Coal complex	Rooms cleaning done
SCR 2	Slew 30 degree limits kept in ckt
SCR 4	Cabin top lamp fixture replaced
CCR road	One 120W LED fixture replaced
CC 107/108	70W SV fixtures provided
CC 31,33,37,38,40,42,43,45,104,107,125 ,SCR 2,4,5,6,7,9	Running inspection was done and noted the defects
SCR 4	PCRD motor brake adjusted
CC 39,40	Feed table interlock ZSS cage relocated
CC 34,SCR 1,CC 105,SCR 10,CC 58, 58TT	PPM was done