



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 25/07/2025

Area: OHP

Equipment	Job
co-30,31	hoists ppm is done.
co-24,30,31	motor and panel ppm is done
eot-2	brakes inspection done and regulated along with mechanical.
crusher-2	motor trail run taken and direction checked.
lc-5 to om-9 profibus cable	dressing is done
jh o-2 gallery	illumination is improved.
co-6,9,12, tis on co-6	motor and panel side ppm is done.
co-5,9,6 brs	brs kept in circuit on operation request
co-69	schneider MPR is installed in place of CTMF relay.