



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 04/01/2026

Incharge(s): Amit Roy

Shift: A

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|-----------------|-----------------------|---|----------|----------|---------|
| 1 | OHP | CO-34 | Reported tripped | OLR acted.Reset done | 07:30:00 | 07:35:00 | |
| 2 | CHP | CC-131 | Reported tripped | OLR acted.Reset done(2 times) | 06:45:00 | 08:45:00 | |
| 3 | CHP | Cc-117 | Reported tripped | OLR acted.Reset done | 09:50:00 | 10:00:00 | |
| 4 | CHP | CC-51 | MPD acted | Feeding conveyor stopped.Reset done(10 times) | 06:50:00 | 11:30:00 | |
| 5 | CHP | CC 104 SCR-9 | Slew not taking place | Contactor auxiliary contact stuck.Rectified and tested okay | 07:40:00 | 08:25:00 | |
| 6 | CHP | Cc-39 SCR-6 | Slew not taking place | Limit acted.Slew reverse done(2 times) | 11:45:00 | 13:30:00 | |
| 7 | WT | OT-2 | Reported tripped | Drive-1 tripped on PGEF-1 fault.Reset done | 11:35:00 | 11:40:00 | |
| 8 | IOSA | OC-25A | Reported tripped | OLR acted.Reset done | 08:00:00 | 08:15:00 | |