



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 20/02/2026

Area: CHP

Equipment	Job
JH 209	Sump pump replaced and kept in auto
CC 35,36,38,106,222,SCR 3,4,6,S 1	Running inspection was done
SCR 9	Luff UP limit adjusted as per operation requirement
CC 213	Drive end chute sensor modified with Liner sheet
CC 215,217,220,106	PPM WAS DONE