



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 22/11/2025

Area: OHP

Equipment	Job
jh o-5,6	hoist and ldb maintenance is done.
jh o-2 hoist	mpcb was tripping, replaced and tested
wbr on co-26	ppm is done
co-59,60,61,62,63,64,65,66,67	cjd's ppm is done
co- 61,64,rco-1a	safety devices ppm is done
rco-1a	motor and panel ppm is done