



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 30/09/2025

Area: WT

Equipment	Job
OT 1 Series	Running inspection done found normal
OP 5	checked @ parking zone,found bottom pad flush marking and jumpers loose, tightened
OP 2,3,4 and 6	After rake , maintenance done