



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 28/07/2025

Shift: A

Incharge(s): K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	WOBR ON CO-29	LT NOT TAKING PLACE M-4 OLR ACTED	RESET	08:00:00	08:10:00	
2	OHP	CO-76R	OLR ACTED	RESET	07:45:00	07:55:00	
3	OHP	CO-10A	OLR ACTED	RESET	06:55:00	07:00:00	
4	OHP	CO-35	OLR ACTED	RESET	09:00:00	09:10:00	
5	OHP	BF-7A	REPORTED RED CHECKED GLASS FUSE BLOWN IN CJB	GLASS FUSE REPLACED THAN OK	09:00:00	09:20:00	
6	OHP	CO 29	OLR ACTED(2TIMES)	RESET	09:00:00	09:45:00	
7	OHP	CO 26	OLR ACTED	RESET	09:50:00	10:00:00	
8	OHP	CO4A	BRS ACTED	SENSORS CLEANED THAN OK	12:55:00	13:10:00	
9	OHP	CC 111 S1	B/C FREQUENTLY STOPPING INTR LOCK ZS CAGE STUCK UP	ZS CAGE REPLACED WITH NEW ONE	11:00:00	11:15:00	
10	CHP	CC 117	OLR ACTE4D	RESET	06:00:00	06:15:00	
11	CHP	CC 111 (R1)	B/C NOT RUNNING YARD INTER LOCK ZS CAGE STUCK UP	ZS CAGE FREE IT THAN OK	06:55:00	07:10:00	
12	CHP	CC 36(S2)	LUFFING NOT WORKING HOSE PIPE LINE OIL LEAKAGE	INFORM TO MECH	07:00:00	07:10:00	
13	CHP	CC 33 SCR 4	ALL DRIVES NOT RUNNING	OPERATOR CABIN SIDE MAINS ON THAN OK	07:15:00	07:25:00	
14	CHP	CC-34	OLR ACTED	RESET	08:10:00	08:20:00	
15	CHP	CC 36	PCRD POWER CONTACTOR R PHASE OUT GOING PROBLEM	CONTACTOR REPLACED PCRD CABLE LAYERING WAS DONE	11:20:00	11:40:00	



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 28/07/2025

Incharge(s): K SANKARA RAO

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
16	CHP	CC 125	OLR ACTED	RESET	12:30:00	12:40:00	
17	CHP	CC33 SCR 4	SLEW AND B/W STOPPING FREQUENTLY CHARGE PRESSER BIT MISSING	P2 BIT BYPASSED THAN INFORMED TO MECH	12:00:00	13:00:00	
18	CHP	CC 32 SCR 5	B/C NOT RUNNING MPD TRIP	RESET	12:50:00	13:05:00	
19	IOSA	OC-13A	REPORTED NOT RUNNING HVMCC-6 I/C- 1 TRIP PULL CHORD ACTED	I/C -1 CHARGED AND PULL CHORD BYPASSED THAN OK	10:45:00	11:20:00	