



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 18/09/2025

Incharge(s): Arnab Roy

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	C0 12	Tripped , carriage drive MPCB acted	reset done	01:55:00	02:10:00	
2	CHP	CC 51	MPD tripped	reset	22:30:00	06:00:00	
3	CHP	CC 32	MPR tripped	reset	22:15:00	22:25:00	
4	CHP	CC 31, SCR 4	LT not running	track jamming , informed operation	23:20:00	23:40:00	
5	CHP	CC 39 , SCR 3	LT not working , jamming	informed to operation	03:30:00	03:50:00	
6	CHP	CC 39	Tripped on overload	reset	05:00:00	05:10:00	
7	WT	EOT Crane ore	main power contactor outgoing B phase lug damaged	replaced and climping done	22:15:00	22:30:00	