



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 08/06/2025

Shift: A

Incharge(s): Lal Singh, Arnab Roy

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|---------------|----------------------------------------------|------------------------------------|----------------------|----------------------|---------------------------------|
| 1 | OHP | WOBR on CO 6A | LT not working due to PCRD overtension | tension released , then ok | 06:50:00 | 07:05:00 | |
| 2 | OHP | V F 2A | Drive tripped due to coal side motor burn | Motor changed | 07:00:00 | 14:00:00 | Informed operation for cleaning |
| 3 | OHP | TT 2 on CO 21 | Position indication not coming | Fuse TB loose , connected properly | 07:25:00 | 07:35:00 | |
| 4 | OHP | CO 77 | Overload acted | reset done | 13:15:00 | 13:20:00 | |
| 5 | OHP | CR 1A | Stopping on high vibration | Vibration showing 50 continuously | 13:00:00 | 13:30:00 | Informed to instrumentation |
| 6 | CHP | CC 39 , SCR 7 | BW not running | Fault reset done in operator cabin | 07:10:00 | 07:20:00 | |
| 7 | CHP | CC 32 , SCR 5 | BC not running | Fault reset done in operator cabin | 07:45:00 | 07:50:00 | |
| 8 | CHP | CC 39 , SCR 7 | LT not working due to PCRD overtension acted | tension released , then ok | 10:55:00 | 11:10:00 | |
| 9 | CHP | CC 33 | Tripped in overload | reset | 12:05:00 12:40:00 | 12:15:00 12:45:00 | |
| 10 | CHP | CC 32 | Tripped in overload | reset | 12:15:00 | 12:20:00 | |
| 11 | CHP | CC 201 | Tripped in overload | reset done | 12:25:00 | 12:30:00 | |
| 12 | CHP | CC 54 | Tripped in overload | reset done | 09:15:00 | 09:20:00 | |
| 13 | CHP | CC 131 | Tripped in overload | reset done | 13:40:00 | 13:45:00 | |



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 08/06/2025

Incharge(s): Lal Singh, Arnab Roy

Shift: A

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|----------------------------|-----------------------------------------|-----------------------|----------|----------|---------|
| 14 | WT | OP 7 | Not moving , individual breaker tripped | made on | 10:00:00 | 10:15:00 | |
| 15 | WT | CP 2 and CP 4 | Communication problem | PLC recycled at cabin | 11:20:00 | 11:40:00 | |
| 16 | WT | 7A / 5A material selection | 5a kept in dolo | At LC 1 | 11:00:00 | 11:10:00 | |