



वी.एस.पी  
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 25/08/2025

Shift: A

Incharge(s): Nagendra Midde,P Venkat Kiran

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co36A	STOPPING on zss	Due to overload at t/e side,	12:20:00	12:35:00	informed operation
2	OHP	co51 beltdrive	tripped on Thermal OLR twice	due to heavy material	07:20:00 09:30:00	07:30:00 09:45:00	reset done after clearing
3	OHP	co51 zss	zss fuse blown at middle jb	due to festoon cable insulation damaged,	10:45:00	11:00:00	taping done and cable rearranged
4	OHP	tbs-24 and brc-34	no power	falsh over in coupler of tbs-24 is observed and 2 fuses blown,	11:00:00	14:00:00	brc-34 is charged abd dnw is informed .
5	CHP	cc 54	tripped on olr , 6 times	reset done	07:00:00	09:00:00	
6	CHP	cc-51	mpd tripped and feeding conveyor stopped 3 times	reset done	11:00:00	12:30:00	
7	CHP	R1 CC 33	B/C ZSS INTERLOCK CAGE STUCKED WITH COAL	REMOVED	08:15:00 08:50:00	08:15:00 09:00:00	
8	CHP	SCR 10 ON CC 105	B/C STOPPED ON EARTH FAULT	RESET	12:40:00	12:50:00	
9	CHP	S1 ON CC 37	PCRD CABLE WINDING DONE	AFTER MACH CLEARENCE	12:15:00	13:00:00	
10	CHP	CC 107	OLR ACTED	RESET	13:05:00	13:10:00	
11	CHP	CC 27A	T/T C/S ACTED	PROBE CLEANED THEN OK	11:40:00	11:50:00	