



वी.एस.पी  
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 23/09/2025

Incharge(s): Amit Roy,K SANKARA RAO

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-10A	OLR ACTED	RESET DONE	15:00:00	15:20:00	
2	OHP	BRC ON CO-28	REPORTED B/W-1,B/W-2 NOT RUNNING CHECKED AND FOUND BOTH POWER MCCB OFF CONDITION	B/W-1 AND B/W-2 POWER MCCB MADE ON	20:00:00	20:30:00	
3	OHP	CO-9	OLR ACTED	RESET DONE	21:25:00	21:35:00	
4	OHP	WOBR ON CO-25	INTERLOCK ZSS CAGE STUCK UP WITH STONE	STONE REMOVED THAN OK	21:30:00	21:45:00	
5	CHP	CC-54	OLR ACTED	RESET DONE	17:15:00	17:20:00	
6	CHP	CC-117	OLR ACTED	RESET DONE	20:35:00	20:40:00	
7	CHP	CC-51	OLR ACTED (4TIMES) DUE TO FEEDING CONVEYOR STOP	RESET DONE	19:30:00	21:00:00	
8	CHP	CC-38	REPORTED C/S NOT HEALTHY CHECKED AND FOUND COAL MATERIAL JAMMING	SENSOR CLEAN THAN OK	15:20:00	15:30:00	
9	CHP	CC-37 SCR-7	REPORTED SLEW NOT WORKING CHECKED SPIDER ALARM FILTER P2 FULL THAN INFORMED TO MECHANICAL	FILTER POSITION CHANGE THAN SPIDER RESET SLEW PUMP ON THAN SLEW OK	19:20:00	19:50:00	