



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 25/07/2025

Area: OHP

Equipment	Job
co-30,31	hoists ppm is done.
co-24,30,31	motor and panel ppm is done
eot-2	brakes inspection done and regulated along with mechanical.
crusher-2	motor trail run taken and direction checked.
lc-5 to om-9 profibus cable	dressing is done
jh o-2 gallery	illumination is improved.
co-6,9,12, tis on co-6	motor and panel side ppm is done.
co-5,9,6 brs	brs kept in circuit on operation request
co-69	schneider MPR is installed in place of CTMF relay.