



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 25/10/2025

Area: WT

| Equipment | Job |
|-----------|--|
| AF 4(O) | Removed motor shifted to tippler house and checked winding values found ok |
| AF 4(O) | Motor tested with spare drive found Ok |
| OP 4 | After rake maintenance done |