



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 26/09/2025

Shift: C

Incharge(s): Nagendra Midde

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 28	OLR ACTED	RESET	01:45:00	01:55:00	
2	OHP	CO16	OLR ACTED	RESET	04:50:00	05:00:00	
3	OHP	CO 29	OLR ACTED	RESET	22:40:00	22:50:00	
4	OHP	TBS ON CO 21	LBC ZSS CAGE GOT STRUCK	MADE IT FREE	22:30:00	22:50:00	
5	OHP	CO 10A	OLR ACTED	RESET	02:00:00	02:10:00	
6	OHP	RSCO 6 C/D	OLR ACTED	RESET	04:00:00	04:10:00	
7	OHP	CO 13A	BRS LOOSE CONNECTION IN MODULE	TIGHTENED	05:45:00	06:00:00	
8	CHP	SCR 4 ON CC 31 B/C	C/S ACTED DUE TO WET COAL	CLEANED THEN OK	23:30:00	23:55:00	
9	CHP	SCR 4 ON CC 31	LT O/T ACTED	RELEASED	01:55:00	02:15:00	
10	CHP	CC 125	OLR ACTED	RESET	00:35:00 04:00:00	00:45:00 04:10:00	
11	CHP	SCR 7 ON CC 37	SLEW OIL LEVEL LOW	INFORMED TO MECH	03:25:00	03:45:00	
12	CHP	SCR 1 ON CC 36	LUFF OIL LEAKAGE	INFORMED TO MECH	03:50:00	04:00:00	
13	IOSA	OC 25A	OLR ACTED	RESET	05:00:00 05:30:00	05:10:00 05:40:00	