



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 04/12/2025

Area: WT

| Equipment      | Job  |
|----------------|--|
| MIS            | COMBIUM make set of modem/Antenna installed @ O7 and OT 4 found communication OK |
| MIS            | Air Compressors 1 and 2,panels blowing done and Comp 2(NEW) kept on running      |
| MIS            | OP 4/D2 removed motor @ maintenance zone , meggaring done found OK               |
| LC 10 A        | Space Heaters supply checked found available in both T1 and T2 .                 |
| LC2A           | cable laid and supply provided foe space heater with MCB control in T1 room      |
| LC 2A and 10A  | Feeder 2 ,racked In and charged  |
| OP 1,4,6 and 8 | After rake maintenance done  |