



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 23/05/2025

Shift: B

Incharge(s): K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO29	OLR ACTED (2TIMES)	RESET	19:00:00	19:10:00	
2	OHP	CO 9	BRS	BY PASSED OPERATION REQUIREMENT	20:45:00	20:50:00	
3	OHP	BRC ON CO33M	B/C OLR ACTED	RESET	21:00:00	21:15:00	
4	OHP	BRC ON CO30	B/C OLR ACTED	RESET	21:15:00	21:30:00	
5	CHP	cc 131	tripped on olr	reset done	17:05:00	17:10:00	
6	CHP	cc 108	brs kept in ckt	operation request	16:00:00	16:10:00	
7	CHP	cc 107	brs bypass request from ope.	bypassed	16:00:00	16:10:00	
8	CHP	scr 5 on cc32	bc c/s acted and probe damaged and fuse bloen	probe and fuse replaced .then ok	16:40:00	17:00:00	
9	CHP	CC 104 , SCR 9	Luffing lower limit lever found removed condition	Lever fixed properly , checked ok	18:40:00	18:50:00	
10	CHP	CC 32, SCR 5	Slewing not working	30 degree left limit acted , informed operation .	20:20:00	20:30:00	
11	CHP	CC 35 , SCR 2	LT not working due to PCRD overtension	Overtension released, then LT working	21:15:00	21:25:00	
12	CHP	CC 36	BRS bypass request from operation	Bypass done	21:15:00	21:20:00	In system
13	CHP	CC 25	OLR acted	reset done	20:30:00	20:35:00	