RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 12/11/2026

Shift: A

Incharge(s): Nagendra Midde

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 25	OLR acted	Reset	06:30:00	06:35:00	
2	OHP	WBr on CO 29 No power	ACb trip	Made it on	07:10:00	07:20:00	
3	OHP	CO 26	OLR acted	Reset	07:25:00	07:30:00	
4	OHP	TBS on CO 19 Left luff	OLR acted	Reset	08:35:00	08:50:00	
5	OHP	CO 60 ZSs	Probe Problem	Replaced	09:10:00	09:30:00	
6	CHP	CC 131	OLR acted	Reset	12:15:00	13:00:00	2 times