



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 16/05/2026

Area: CHP

Equipment	Job
CC 7	Sump pump panel control ckt problem rectified and de watered
CC 9,29, CC 29TT	PPM was done
SCR 2	Luff oil circulating pump connection given and trail run taken
CM 17,CM 19,LC 6,LC 17,LC 18	Earth pit resistance measured and noted
CC 52,53,VS 3,VF 3,CC 215,216,217,218,220,221	PPM was done
LC 2	Rooms cleaning under progress